



ASSUMPTIONS/REQUIREMENTS

- 1) ACCESSIBLE WATER CLOSET DEPTH IS 30 INCHES AND IT IS FLOOR MOUNTED.
- 2) CONTROLS FOR FLUSH VALVES SHALL BE MOUNTED ON THE WIDE SIDE OF THE TOILET AREAS (FACBC 11.4.16.5).
- 3) TOILET ROOM DOOR OPENING WIDTH TO BE A MINIMUM OF 32 INCHES (FACBC 11.4.13.5).
- 4) TOILET ACCESSORIES TO BE PROVIDED.
- 5) GRAB BARS TO COMPLY WITH 11.4.26 AND FIG. 29.
- 6) DOOR WIDTH IS 36 INCHES

Larry M. Schneider Copyright 2010 04/12/10

VERY IMPORTANT NOTE:

THESE ARE ONLY TWO POTENTIAL DESIGNS FOR A TOILET ROOM OUT OF 5000 +DESIGNS

TYPICAL ACCESSIBLE TOILET ROOM

COMPLYING WITH THE REQUIREMENTS OF THE FLORIDA LAW AND THE ADAAG STANDARDS

1/4" = 1'-0"