



ASSUMPTIONS

- 1) ACCESSIBLE WATER CLOSET DEPTH IS 30 INCHES AND IT IS FLOOR MOUNTED.
- 2) CONTROLS FOR FLUSH VALVES SHALL BE ON THE OPEN SIDE OF THE WATER CLOSET (FACBC 604.6).
- 3) TOILET ACCESSORIES TO BE PROVIDED.

NOTE:

ACCESSIBLE TOILET STALL CAN BE 56" IN DEPTH IF YOU HAVE A WALL MOUNTED WATER CLOSET. IF THE DEPTH OF A STANDARD ACCESSIBLE TOILET STALL IS INCREASED AT LEAST 3 INCHES, THEN A FLOOR MOUNTED WATER CLOSET MAY BE USED. WE RECOMMEND A DEPTH OF 60" (FACBC 604.8.1.1).

DO NOT FORGET THE REQUIREMENT OF THE "6th" TOILET STALL (COUNTING TOILETS & URINALS) TO BE AN AMBULATORY ACCESSIBLE TOILET COMPARTMENT (FACBC 213.3.1).

Larry M. Schneider AIA Copyright 2012 04-01-2012

GENERAL NOTES:

**THE SINK SHALL BE A MINIMUM OF 15 INCHES FROM THE SIDE WALL TO THE CENTERLINE AS REQUIRED BY SECTION 405.3.1 OF THE FPC.

ACCESSIBLE LAVATORY IN COMMON AREA 213.3.4-WHERE LAVATORIES ARE PROVIDED, AT LEAST ONE SHALL COMPLY WITH 606 AND SHALL NOT BE LOCATED IN A TOILET COMPARTMENT.

604.7 - TOILET COMPARTMENTS CONTAINING MORE THAN ONE PLUMBING FIXTURE SHALL COMPLY WITH 603. I.E. - PROVIDE A TURNING SPACE COMPLYING WITH 304 (60" CIRCULAR SPACE OR A T-SHAPED SPACE).

THIS TECHNICAL ASSISTANCE DOCUMENT IS INTENDED TO PROVIDE INFORMAL GUIDANCE AND DOES NOT CONSTITUTE A LEGAL INTERPRETATION OF STATUTORY OR REGULATORY CRITERIA

TYPICAL ACCESSIBLE TOILET STALL FOR NEW CONSTRUCTION ONLY

COMPLYING WITH THE REQUIREMENTS OF THE FLORIDA LAW AND THE ADAAG STANDARDS

1/4"=1'-0"